

Country report for Peru

50%

Criteria	Question	Weight	Score
Standards & rules	Are standards and rules in place?	10	Fulfilled
Answer: 10/10			
Initial verification	Is an initial inspection required?	10	Fulfilled
Answer: 10/10			
Periodic inspection	Is a periodic inspection required?	7.5	Fulfilled
Answer: 7.5/7.5			
Inspection report	Must there be proof of the inspection by the delivery of an inspection report?	5	Partially fulfilled
Answer: 2.5/5			
Inspection for existing installations	Is there a mechanism for inspection of existing installations?	10	Partially fulfilled
Answer: 5/10			
Inspector	Must the person carrying out the inspection be a qualified inspector?	7.5	Fulfilled
Answer: 7.5/7.5			
Electrical contractor or installer	Must the electrical contractor or installer be a qualified person?	5	Fulfilled
Answer: 5/5			

Role of utilities	Does the electric utility only connect the installation after having received a positive inspection report?	10	Not met
-------------------	---	----	---------

Answer: 0/10

Consumer education	Are consumers educated on the dangers of electricity?	5	Not met
--------------------	---	---	---------

Answer: 0/5

Regulation	Is regulation in place that imposes standards for electrical installations and initial verification?	5	Partially fulfilled
------------	--	---	---------------------

Answer: 2.5/5

Labelling and certification	Are products in the market adequately labeled for electrical safety, and is this labeling system understood?	5	Unknown
-----------------------------	--	---	---------

Answer: ?

Role of manufacturers	Do manufacturers actively engage for electrical safety in the marketplace?	5	Unknown
-----------------------	--	---	---------

Answer: ?

Market surveillance	Is there adequate action on market surveillance from the authorities?	15	Unknown
---------------------	---	----	---------

Answer: ?